RMK-12 ENERGY AUDIT CONDITIONAL GRANT (EACG)

Develor

ENERGY AUDIT GUIDE

(FOR COMMERCIAL BUILDINGS)

BY

SUSTAINABLE ENERGY DEVELOPMENT
AUTHORITY

(SEDA MALAYSIA)

Table of Contents

| 1.0 | ENERGY AUDIT | 3 |
|-----|---|----|
| 2.0 | METHODOLOGY OF ENERGY AUDIT | 3 |
| 3.0 | SCOPE OF WORK ENERGY AUDIT | 5 |
| 3.1 | Energy management of the building; | 5 |
| 3.2 | Energy supply information; | 6 |
| 3.3 | Energy usage information; | 6 |
| 3.4 | Energy saving potential and measures (ESMs) | 9 |
| 3.5 | Financial analysis | 11 |
| 3.6 | Financial and Energy Saving Implementation Planning (3 Years) | 10 |
| 4.0 | MANDATORY REQUIREMENT | 11 |

1.0 ENERGY AUDIT

Energy audit is an important tool in establishing the energy supply and consumption pattern and the measures that need to be taken to optimize energy usage in buildings. Energy audit is an important effort to facilitate the building owners / ESCO to identify the energy saving potentials and to promote efficient use of energy,

The reference in this document stipulate the objectives, scope of work, deliverables, and other requirements of energy audit to be conducted at selected commercial buildings that consume high electrical energy.


Thus, the building owners and ESCOs must comply with the terms of reference provided in order to conduct and produce a good, systematic and quality audit exercise, as well as uniform and comprehensive reports.

The objectives of the Energy Audits are;

- To identify the energy supply information and status;
- To identify the current energy management program, setup, policy, implementation, and effectiveness.
- To identify present and historical energy usage pattern;
- To identify where the wastage occurs and measures to be taken to optimize consumption and reduce wastage; and
- The findings of this audit will be used to assist the building owner to formulate energy management plan and implement the relevant energy saving measures (ESMs) recommended in the energy audit report.
- Providing detail technical solutions and estimated cost in the energy audit report.

2.0 METHODOLOGY OF ENERGY AUDIT


- √ Kick-off meeting
- √ Walk through
- √ Site investigation and measurement
- √ Data analysis
- √ Data verification
- √ Report Writing
- $\sqrt{}$ Presentation of result
- √ Feedback from all parties
- √ Submission of final report



The energy audit approach and process normally involve;

- Obtain and study the historical data of the building in order to establish baseline;
- ii. Identify the current weakness or energy wastages;
- iii. Propose the technical solutions to minimise the wastages;
- iv. Evaluate and perform economic efficiency or life cycle costing analysis; and
- v. Develop recommendation and action plan.

Approach of energy audits



3.0 SCOPE OF WORK ENERGY AUDIT

The main component of the audit shall cover the following:

3.1 Energy management of the building;

- To review Operation and Maintenance Contract including budget required;
- To review existing Energy Efficiency Policy/Energy Management System;

- To review documents and data pertaining to energy usage;
- To review Organizational Structure and Resource Allocation for Energy Management; and
- To obtain building information on total occupied and air- conditioned areas.

3.2 Energy supply information;

- Tariff structure;
- Maximum demand value and charges;
- Voltage level;
- Historical supply information (preferably 5 years-subject to age of building); and
- Power factor.

3.3 Energy usage information;

- To conduct power distribution profile monitoring and analysis for overall electrical supply (compulsory) and main electrical powered equipment (if available) at least for a period of 14 days;
- To conduct electrical energy load loss survey and site evaluation for the transformers and UPS system after the meter (if necessary and have potential energy savings);
- To study on the energy usage for all equipment and systems.
- To establish electricity consumption distribution based on equipment/systems e.g. air-conditioning, lighting, office equipment etc. in kWh and percentage;
- To establish Energy Indices for each building;
 - Building Energy Index (BEI) kWh/m2/year (Please refer to document, Method to Identifying BEI by SEDA Malaysia and GreenTech Malaysia);
 - Net Building Energy Index (BEI) kWh/m2/year (if renewable energy system available);
 - Building Energy Intensity Index (BEII), kWh/m2/year/person;

- Lighting Energy Intensity Index (LEII), kWh/m2/year/person;
- Air-conditioning Energy Intensity Index (ACEII)
 kWh/m2/year/person; and
- o Building power baseload (extract from the building profile), kW.
- To establish Power Indices for the building;
 - Lighting Power Density [W/m2]
 - Air-conditioning Power Density [W/m2]
 - Equipment Power Density [W/m2]
 - Baseload power index (Baseload / NFA) [W/m2]
- Passive System;
 - Window
 - shading / glazing level
 - design and opening
 - o Wall / Roof
 - types of insulation
 - material and colour
 - Day lighting opportunities
 - To determine OTTV, RTTV (estimate)
 - Building orientation and footprint
 - Availability of natural ventilation and opportunities
 - Roof structure
 - pitch
 - material and colour
 - Ceiling
 - height
 - material, colour
 - o Floor material and colour
 - Landscaping

Active System;

- Air Conditioning System
 - To identify technical information for key air-conditioning equipment such as chiller, AHU and split units;
 - To identify and study operating schedule;
 - To identify control system being used (automatic/manual);
 - To conduct power measurement and analysis for air conditioning system;
 - To carry out air flow, chilled water temperature, air temperature, and analysis for all AHU;
 - To conduct pump system efficiency (depend to site condition);
 - To conduct chilled and condenser water supply and return temperature and flow rate measurement;
 - To calculate overall System Coefficient of Performance;
 - To calculate Coefficient of Performance for chillers;
 - To conduct temperature, CO₂ and Relative Humidity (RH)
 level survey; and
 - To conduct Variable Air Volume (VAV) zoning and air change analysis (if any).

o Lighting

- To prepare a list of types of lamps used and its rated power at internal and external areas (fluorescent, CFL, LED etc);
- To study lighting operating schedule;
- To conduct measurement and analysis of lighting fitting layout and lux level;
- To conduct power measurement and analysis; and
- To conduct lighting control systems and zoning analysis

- Ventilation System / Indoor Air Quality & Infiltration
 - To identify control system being used (automatic/manual);
 - To study ventilation system operating schedule;
 - To conduct air flow measurement and analysis;
 - To conduct energy and power measurement for selected fan;
 - To conduct CO and CO₂ level measurement and analysis; and
 - Analysis on zoning and air change measurement.

Building Automation System (BAS)

- To confirm the function of the BAS facilities and parameters being controlled;
- To perform measurement variation study between actual and the reading in the system; and
- To study the characteristic of BAS in term of monitoring, control and reporting.

Office Equipment

 To survey identify the types of office equipment (printers, computers, photocopy machine, etc) in each room and area with its power consumption (rated capacity, performance rating etc).

3.4 Energy saving potential and measures (ESMs)

ESMs (action plan and estimated time required to implement the measure recommended, amount of saving and cost of implementation). The ESMs shall address the energy management and energy efficiency. Renewable energy can be included but it is not part of the energy audit scope.

- Energy Saving Measures and Recommendations
 - o Text
 - Describe the proposed energy savings measures
 - A list of equipment potential credible suppliers

Chart

- Graphical illustration
- Existing and proposed system (if applicable)

o Photo

- Existing situation
- Proposed equipment sketches or sample photo from manufacturer catalogue
 To list opportunities for electrical energy saving measures identified (saving to systems / equipment / control / monitoring / management) in tables
- Each measure should have tables consisting:
 - The assumptions used in estimating the energy savings
 - The methods used in estimating the savings
 - Technical calculation
 - The conditions to achieve the savings
- To identify detailed methods to achieve savings/electrical energy reduction according to;
 - No cost/ min cost changes of time and operation methods,
 minor repair / improvements
 - Low and high cost or Medium cost based on percentage
 - High cost measure
- To estimate total potential electrical energy saving in kWh;
- To propose an action plan and the estimated time required to implement each saving measure if the management decides to implement it; and
- To propose methods of measurement and calculation to quantify energy savings based on identified saving potentials.

3.5 Financial analysis

Normally involved basic life cost cycle analysis for the proposed energy saving measures (SPP, ROI)

- Measures and costs
- Each measure and potential saving
- Expected return of investments from financial evaluation tools (e.g. SPP, ROI etc.) in years or months.

3.6 Financial and Energy Saving Measures Implementation Planning for the Owner to Implement (3 Years)

Brief budget and implementation planning for building owner to implement within the 3 years.

- 1ST Year, estimated implementation cost and savings.
- 2ND Year, estimated implementation cost and savings.
- 3rd Year, estimated implementation cost and savings.
- * The ESMs implementation planning shall address the energy management and energy efficiency. Renewable energy can be included but it is not part of the Energy Audit Conditional Grant scope. The total cost and savings from renewable energy are not counted as implementation and savings achieved under this EACG scheme.

4.0 MANDATORY REQUIREMENT

Energy audit report must be according to the Energy Audit Report Template as in **Appendix A**.

LAMPIRAN 3

Prepared and updated by, SEDA Malaysia

Mobile: +603 8870 5849 / +603 8870 5814 / 019-2829102 for any enquiry

Building picture/s

Develop

FOR Building Name

Prepared By

Company logo

Client logo

Auditor Name and Address

Client Name and Address

Under



SUSTAINABLE ENERGY DEVELOPMENT AUTHORITY MALAYSIA

CONFIDENTIALITY

This document contains information for the sole perusal of

DISCLAIMER

XXXXX. has no personal or financial interest in supplying or installing equipment for this document.



Table of Contents

| Tā | able of | Contents | 3 |
|----|---------|---|----|
| 1 | EXE | CUTIVE SUMMARY | 6 |
| 2 | INT | RODUCTION | 9 |
| | 2.1 | Objective | 9 |
| | 2.2 | Methodology | 9 |
| | 2.3 | Type of Energy Audit and Process | |
| | 2.4 | Scope of work | |
| | 2.5 | Time Schedule and Audit Framework | 10 |
| | 2.6 | Energy Audit Equipment | 10 |
| 3 | ENE | RGY MANAGEMENT SYSTEM REVIEW | 11 |
| | 3.1 | Policy and targets | 11 |
| | 3.2 | Energy data, documentation and monitoring | 11 |
| | 3.3 | Compliance towards regulations | 11 |
| | 3.4 | Energy management team | 11 |
| | 3.5 | Energy audit team | |
| | 3.6 | Energy Management Matrix | 11 |
| | 3.7 | Operation and Maintenance System Review | |
| 4 | BUII | LDING DESCRIPTION | 13 |
| | 4.1 | General Description and Operation Hours | 13 |
| | 4.2 | Building Orientation and footprint | 13 |
| | 4.3 | Building Envelope | 13 |
| | 4.4 | Daylighting opportunities | |
| | 4.5 | Natural ventilation | 15 |
| | 4.6 | Ceiling – height, material and colour | 15 |
| | 4.7 | Floor material and colour | 15 |
| | 4.8 | Landscaping | 15 |
| 5 | ELEC | CTRICAL SUPPLY INFORMATION | 16 |
| | 5.1 | Tariff | 16 |
| | 5.2 | Historical Energy Consumption | 16 |


| 6 | E١ | NERGY CONSUMPTION INFORMATION AND ANALYSIS – ELECTRICAL | . 17 |
|----|-------|--|------|
| | 6.1 | System Description | . 17 |
| | 6.2 | Load Profile – Electrical | . 18 |
| | 6.3 | Energy load survey and site evaluation for transformers and UPS system | . 18 |
| | 6.4 | Observations and Findings | . 18 |
| 7 | E١ | NERGY CONSUMPTION INFORMATION AND ANALYSIS – CHILLED WATER SYSTEM | . 19 |
| | 7.1 | System description | . 19 |
| | 7.2 | Load Profile – Thermal/Chilled Water | . 19 |
| | 7.3 | Observations and Findings | .21 |
| 8 | E١ | NERGY CONSUMPTION INFORMATION AND ANALYSIS - AIR CONDITIONING AND MECHANICAL | |
| ٧ | ENTIL | ATION SYSTEM | .22 |
| | 8.1 | System Description | . 22 |
| | 8.2 | Observations and Findings | . 25 |
| 9 | E١ | NERGY CONSUMPTION INFORMATION AND ANALYSIS - LIGHTING SYSTEM | .26 |
| | 9.1 | System Description | . 26 |
| | 9.2 | Observations and Findings | . 26 |
| 10 | | ENERGY CONSUMPTION INFORMATION AND ANALYSIS - VERTICAL TRANSPORT (LIFTS AND | |
| E: | SCALA | ATORS) | . 27 |
| | 10.1 | System Description | . 27 |
| | 10.2 | Observations and Findings | . 27 |
| 1: | 1 | ENERGY CONSUMPTION INFORMATION AND ANALYSIS - GENERAL EQUIPMENT AND PLUG | |
| L(| DADS | | |
| | 11.1 | Observations and Findings | . 28 |
| 1 | 2 | ENERGY CONSUMPTION INFORMATION AND ANALYSIS - BUILDING CONTROL SYSTEM | . 29 |
| | 12.1 | System Description | . 29 |
| | 12.2 | Observations and Findings | .30 |
| 13 | 3 | LOAD APPORTIONING AND ENERGY INDEX | .31 |
| 14 | 4 | ENERGY SAVING MEASURES | .33 |
| 1 | 5 | ENERGY SAVING MEASUREMENT AND VERIFICATION | .35 |
| 1 | 5 | ENERGY SAVINGS MEASURES IMPLEMENTATION PLANNING FOR OWNER TO IMPLEMENT (3 | |
| VI | -ΔRS) | | 35 |

Appendix A


| 17 | CONCLUSION | 36 |
|----|--------------|----|
| 18 | VERIFICATION | 37 |

1 EXECUTIVE SUMMARY

Objectives, scope and type of audit. Key systems and equipment audited.








Describe graph

Brief summarized description of energy saving recommendations and their cost-effectiveness

Appendix A


| No. | ESM | Estimated Savings | | Estimated Investment(RM) | Simple Payback Period (yrs) | Estimated Carbon Reduction |
|-----------------|--|-------------------|------------|-----------------------------|--------------------------------|-------------------------------|
| | | Energy (kWh) | Cost (RM) | | | kgCO2/kWh |
| No Cos | t | | | | | |
| 1 | Decommissioning all non critical ACSU units when chiller plant has been retrofitted | 577587.64 | 306131.45 | 0 | Immediate | |
| Low/Medium Cost | | | | | | |
| 2 | Replace all Incandescent decorative lamps with LED strips/LED lamps | 28539.22 | 15, 5.7 | 1,000.00 | 0.07 | 21,147.56 |
| 3 | Switch off outdoor corridor lights during the daytime | 55 1 .85 | 9,384.71 | 80000 | 2.7 | 41,083.15 |
| 4 | Repairing compressed air leakage | 190 0 | 2597.00 | 15000 | 5.8 | 3,630.9 |
| High Co | ost | 500 | | | | |
| 5 | Retrofit chillers, chilled water pumps, condenser water pumps, cooling tower and upgrade pipeworks | 380112.00 | 201459.36 | 1190000 | 5.9 | 281,662.9 |
| 6 | Retrofit AHUs and ducting to improve efficacy | 669384.00 | 354773.52 | 359000 | 1.0 | 496,013.54 |
| 7 | Replace all existing fluorescent and CFL lamps with LED lamps | 567599.96 | 300,827.98 | 482,640.00 | 1.60 | 420,591.57 |



Describe chart

41%

Reduction



Based on the CIDB 2012 GreenPASS assessment scheme above, the level of achievement in % carbon reduction is eligible for x diamond certification.



2 INTRODUCTION

Brief explanation on functions, operation hours, occupancy rate, etc.

Building Description

Building Name: Client name

Address: Client address

Building Use: Commercial and Office


In operation since: 2001


2.1 Objective

Brief explanation

2.2 Methodology

Brief explanation






2.4 Scope of work

Brief explanation

2.5 Time Schedule and Audit Framework



2.6 Energy Audit Equipment

List of equipment

3 ENERGY MANAGEMENT SYSTEM REVIEW

3.1 Policy and targets

Policy declaration and brief description of action plans, targets, timeframe, roles and responsibilities

3.2 Energy data, documentation and monitoring

Describe the level of documentation available in the organization, policies, records, regulations, guides, training in relation to energy management

Describe monitoring of energy use procedures, energy performance indicators, effectiveness of action plans in achieving objectives and targets, evaluation of actual vs expected energy consumption – results from monitoring and measurement should be recorded

3.3 Compliance towards regulations

Describe evaluation procedures in complying with legal requirements in relation to energy use and consumption, records

3.4 Energy management team

List names, position and role

3.5 Energy audit team

List names, position and role

3.6 Energy Management Matrix

Energy Management Matrix may be used to determine level of energy management practiced and can be used as a guide for improvement

| | Policy and Systems | Organization | Motivation | Information System. | Training and awareness | Investment |
|---|---|---|---|---|--|--|
| 4 | Formal energy /environmental policy and management system, action plan and regular review with commitment of senior management or part of corporate strategy | Energy / environmental management fully integrated into management structure. Clear delegation of responsibility for energy use | Formal and informal channels of communication regularly exploited by energy / environmental manager and staff at all levels | Comprehensive system sets targets, monitors materials and energy consumption and wastes and emissions, identifies faults, quantifies costs and savings and provides budget tracking | Marketing the value of material and energy efficiency and the performance of energy / environmental management both within the organization and outside it | Positive discrimination in favour of energy / environmental saving schemes with detailed investment appraisal of all new build and plant improvement opportunities |

Appendix A

| | Policy and Systems | Organization | Motivation | Information System. | Training and awareness | Investment |
|---|--|--|--|---|---|---|
| 3 | Formal energy / environmental policy but no formal management system and with no active commitment from top management | Energy / environmental manager accountable to energy committee, chaired by a member of the management board | Energy / environmental committee used as main channel together with direct contact with major users | Monitoring and targeting reports for individual premises based on sub-metering / monitoring but savings not reported effectively to users | Programme of staff training, awareness and regular publicity campaigns | Same pay back criteria as for all other investments. Cursory appraisal of new build and plant improvement opportunities |
| 2 | Unadopted / informal energy / environmental policy set by energy / environmental manager or senior departmental manager | Energy / environmental manager in post, reporting to ad-hoc committee but line management and authority unclear | Contact with major users through ad- hoc committee chaired by senior departmental manager | Monitoring and targeting reports based on supply meter / measurement data and invoice. Env / energy staff have ad-hoc involvement in budget setting | Some ad-hoc staff awareness and training | Investment using short term pay back criteria mostly |
| 1 | An unwritten set of guidelines | Energy or environmental management the part-time responsibility of someone with only limited influence or authority | Informal contacts between engineer and a few users | Cost reporting based on invoice data. Engineer compiles reports for internal use within technical department | Informal contacts used to promote energy efficiency and resource conservation | Only low cost measures taken |
| 0 | No explicit policy | No energy environmental manager or any formal delegation of responsibility for env/energy use | No contact with users | No information system. No accounting for materials and energy consumption and waste | No awareness raising of energy efficiency and resource conservation | No investments in increasing environmental performance or energy efficiency in premises |

3.7 Operation and Maintenance System Review List scope of works involved for energy management

4 BUILDING DESCRIPTION

4.1 General Description and Operation Hours

Describe building function, occupancy, general services provided

4.2 Building Orientation and footprint

Picture/s of building – side, front, top views

| Description | Gross Floor Area | Air Conditioned Area | Height (m) |
|-------------|------------------|----------------------|---------------|
| Client name | 83,000 | 45,900 | 35 (6 floors) |

4.3 Building Envelope

Overall Thermal Transfer Value (OTTV) and Roof Thermal Transfer Value (RTTV)

WALL CONSTRUCTION

Types of insulation

Material colour

| No. | Description | Thickness (mm) | U-Value (W/m²K) |
|--------|--|-------------------|--------------------|
| 1 | Wall | | ALC: NO |
| | Cement Plaster | 20 | 2.19 |
| EA. | Granite (Solar Absorption Factor, $\alpha =$ | 201 | 2.927 |
| "E a.l | 0.45, Light Grey) | | District Control |
| 2 | Fenestration | | |
| | Laminated toughened tinter ass | 12 | 4.8 |
| 3 | Roof | | -400 |
| | Roof Tile | 20 | 0.6 |
| | Reflective Foil a breglass | 50 | 0.035 |
| | Asbestos Board | 3 | 1.298 |

WINDOW TO WALL RATIO

Shading/glazing level

Design and operation

| Wall | Total Glass Area (m²) | Total Façade Area (m²) | WWR |
|--------------------|--------------------------|---------------------------|------|
| North West Wall | 1037.18 | 8938.715 | 0.12 |
| North East Wall | 355.6 | · 108. 3 | 0.09 |
| South East Wall | 103 12. | 8933.72 | 0.11 |
| South West Wall | 355.60 | 4108.48 | 0.09 |

OTTV OF EACH FAÇADE

| | OTTV (North West) | OTTV (North East) | OTTV (South East) | OTTV (South West) | Total OTTV |
|---|-------------------------|-------------------------|-------------------------|-------------------------|---------------|
| I | 20.34 | 21.28 | 21.39 | 20.34 | 21.02 |

ROOF CONSTRUCTION

Types of insulation

Material colour

| Material | Thickness (m) | Density kg/m3 | k-value W/m K | Resistance (m2K/W) |
|------------------------------|------------------|------------------|------------------|--------------------|
| Outside air film | - | 1 | | 0.06 |
| Roof Tile | 0.02 | 1 9(| 0.836 | 0.02 |
| Reflective Foil & Fibreglass | 0.05 | OLE | 0.035 | 1.43 |
| Asbestos Board | 003 | 720 | 0.108 | 0.03 |
| Inside air film | | | | 0.15 |
| Total Resistance | | | | 1.68 |
| U-Value | | | | 0.59 |

RTTV of each roof direction

| | Gross Roof Area (m2) | RTTV | | |
|------------|-------------------------|----------|--|--|
| Flat Roof | 759 | 10556.1 | | |
| North East | 1490 | 2 44 33 | | |
| North West | 285 | .0734.93 | | |
| South East | . vz1 | 41647.44 | | |
| South Tes | 1522 | 21700.58 | | |
| T talk TV | 16389 | 14.26 | | |

- 4.4 Daylighting opportunities
- 4.5 Natural ventilation
- 4.6 Ceiling height, material and colour
- 4.7 Floor material and colour
- 4.8 Landscaping

5 ELECTRICAL SUPPLY INFORMATION


5.1 Tariff

Describe tariff system used


| Year | Energy Rate (RM/kWh) | Maximum Demand Rate (RM/kW) | | | |
|----------------------|----------------------|--------------------------------|--|--|--|
| June 2011 – Dec 2013 | RM0.312 | RM25.90 | | | |
| Jan 2014- present | RM0.365 | RM30.30 | | | |

5.2 Historical Energy Consumption

Describe energy consumption and cost



Describe energy consumption, maximum demand and costs



Describe load factor and evaluation

6 ENERGY CONSUMPTION INFORMATION AND ANALYSIS – ELECTRICAL

6.1 System Description

Please include the photos/diagram/schematic of the overall view of the electrical distribution and reflecting the energy balance in the premise. This is to make people who read the report can understand the power / load capacity and energy flows, how and where it been used (incoming and outgoing/consumed)

Describe system


Electrical Schematic Diagram



6.2 Load Profile – Electrical

Describe load profile and observations

Highlight baseload readings



6.3 Energy load survey and site evaluation for transformers and UPS system

Describe load loss evaluation for transformers and UPS (if any)

| Description | Tx 1 | Tx 2 | Тх 3 | Tx 4 |
|------------------------|--------|--|--------------|--------------------------|
| Average Efficiency (%) | 94.37% | 94.63% | 94.52% | 94.85% |
| Current Capacity (kVA) | 321.65 | 156.86 | 31.30 | 551.88 |
| 470 | 12.87% | 52.6 | 7.65% | 13.14% |
| Available Capacity (%) | 87.13 | 95.73% | 92.35% | 86.86% |
| Problems Detected | | Dip, swell, interruption and impulse | Interruption | Interruption and impulse |

6.4 Observations and Findings


Describe observations and findings

7 ENERGY CONSUMPTION INFORMATION AND ANALYSIS – CHILLED WATER SYSTEM

7.1 System description


Describe system


Air conditioning schematic diagram



7.2 Load Profile – Thermal/Chilled Water


Describe load profile and observations





Describe chilled water system and operation

| Day | Average Load factor | Average COP | |
|---------|------------------------|-------------|--|
| 01 | 77% | 3.7 | |
| 02 | 82% | | |
| 03 | 88% | 4.5 | |
| 04 | | 4.3 | |
| 05 | . 4% | 4.8 | |
| 06 | 95% | 4.9 | |
| 07 | 94% | 5.1 | |
| Overall | 88% | 4.5 | |



AVERAGE ANNUAL CHILLER PLANT EFFICIENCY IN KW/TON (C.O.P.)

(Input energy includes chillers, condenser pumps and tower fans)

7.3 Observations and Findings

Describe observations and findings

8 ENERGY CONSUMPTION INFORMATION AND ANALYSIS - AIR CONDITIONING AND MECHANICAL VENTILATION SYSTEM

8.1 System Description

Describe system/s

| No | Description | | Total Installed |
|----------|-----------------------------|----|-----------------|
| | | | Power (kW) |
| Main Bui | lding | 1 | |
| 1 | Chilled Water Pumps | 1 | 220kW |
| 2 | Air Handling Units | 4 | 632.2kW |
| 3 | Fan Coil Unit | 30 | 188kW |
| 4 | Variable Refrig ra t Volume | 29 | 100.37kW |
| | (VRV) Unit | | |
| 5 | Ventilati Sai. | 90 | 337.6kW |
| 6 | Cooling Temer Fan | 4 | 200kW |
| 7 | Condenser Water Pumps | 4 | 130kW |

Time schedule of operations

| No | Description | Quantity | Operation Hours | | |
|----------|-------------------------------|----------|-----------------|----------|--|
| | | | Start | Stop | |
| Main Bui | lding | | | TO to be | |
| 1 | Chilled Water Pumps (Duty) | 2 | 6:00am | 6:00pm | |
| 401 | Chilled Water Pumps (Standby) | 2 | 6:00pm | 6:00am | |
| 2 | Rooftop Chiller (Duty) | | 6:00pm | 6:00am | |
| - N. | Rooftop Chiller (Standby) | 1 | 6:00am | 6:00pm | |
| 3 | Air Handling Units (24hr | 25 | 6:00am | 6:00am | |
| 4 | Air Handling Units | 21 | 6:30am | 6:00pm | |
| 5 | Fan Coil Unit (2 hrs | 16 | 6:00am | 6:00am | |
| 6 | Fan Coil Unit | 14 | 7:00am | 6:00pm | |
| 7 | Variable Refrigerant Volume | 28 | 6:00am | 6:00am | |
| 100 | (VRV) Unit | | 1 | | |
| 8 | Ventilation Fans (toilets) | 86 | Manual | | |
| 9 | Ventilation Fans (Fresh air) | 4 | 6.00 a.m | 6.00 p.m | |

Fan Specific Power

Describe findings

| No | AHU | Air Flow R | ate, m³/hr | Fan Power, | Fan Efficiency, | |
|----|--------------|------------|------------|---------------|--------------------|--|
| | | Design | Running | W | W/m³hr | |
| 1 | AHU-L1-MO1.4 | 28,237 | 17,193 | 8,668 | 0.50 | |
| 2 | AHU-L1-MO1.8 | 34,503 | 33,3 1 | 9,833 | 0.29 | |
| 3 | AHU-L1-MO1.9 | 24 45 | 9 39 | 7,439 | 0.78 | |
| 4 | AHU-L2-MQ1.1 | 3, 392 | 25,554 | 9,768 | 0.38 | |
| 5 | AHU-L2-MQ1.2 | 36,621 | 10,602 | 8,345 | 0.79 | |
| 6 | AHU-L2-MO1.5 | 36,358 | 30,991 | 15,202 | 0.49 | |


Air Change Rate (ACR) and AHU Capacity Analysis

Describe findings

| No | AHU | Capacity, Btu/hr | Air Flow Rate, m ³ /hr | | Served Area, m² | rea, Hour (ACH) | | Capacity Intensity, Btu/hr ft ² |
|------|---------------|---------------------|-----------------------------------|---------|-----------------------|-----------------|---------|--|
| 1000 | 10 | 73.5 | Design | Running | | Design | Running | |
| 1 | AHU-L1-M01.9 | 593,688 | 25,269 | 9,539 | 969.2 | 8.5 | 3.2 | 56.9 |
| 2 | AHU-L1-M01.8 | 812,056 | 34,503 | 33,361 | 1,600.9 | 7.0 | 6.8 | 47.1 |
| 3 | AHU-L1-M01.4 | 665,340 | 28,252 | 17 9. | 7, 77.5 | 8.6 | 5.2 | 57.4 |
| 4 | AHU-ANX-L1A.3 | 535,684 | 5,20 | 5,853 | 925.2 | 8.1 | 2.1 | 53.8 |
| 5 | AHU-L2-M01.1 | 880,296 | 37,392 | 25,554 | 1,720.3 | 12.8 | 4.9 | 47.5 |
| 6 | AHU-L2-M01.2 | 863,236 | 36,621 | 10,603 | 1,448.8 | 8.3 | 2.4 | 55.4 |


Indoor Air Quality


Describe findings



Air Conditioning Room Conditions

Describe findings





8.2 Observations and Findings

Describe observations and findings.



9 ENERGY CONSUMPTION INFORMATION AND ANALYSIS - LIGHTING SYSTEM

9.1 System Description

Show list of lighting types and quantity

Describe lighting system and operation

| No | Description | Or option Hours | | |
|-----------|------------------|-----------------|--------|--|
| | | | Stop | |
| Main Buil | ding | | | |
| 2 | Lobby, Walkways | 6:00am | 6:00am | |
| 3 | Offices | 6:30am | 6:00pm | |
| 4 | Outdoor ght, g | 7:00pm | 7:00am | |
| 5 | Declarive inting | 6:00am | 6:00am | |
| 6 | Car Par (24hrs) | 6:00am | 6:00am | |

Lighting Conditions

Describe findings



9.2 Observations and Findings

Describe observations and findings

10 ENERGY CONSUMPTION INFORMATION AND ANALYSIS - VERTICAL TRANSPORT (LIFTS AND ESCALATORS)

10.1 System Description

Describe system and operation

| Room No./ Description | Equipment Description | Rated Power [kW] | Quantity |
|-----------------------|-----------------------|------------------------|----------|
| North Lift | Lift No. 2 | 22 | 1 |
| North Lift | Lift No. 3 | 22 | 1 |
| South Lift | Lift No. 4 | 22 | 1 |
| South Lift | Lift N | 22 | 1 |
| Main Lobby | LtN 6 | 22 | 1 |
| Main Lobby | Lift No. 7 | 22 | 1 |
| OKT Lift | Lift No. 8 | 11 | 1 |
| OKT Lift | Lift No. 9 | 11 | 1 |
| Service Lift | Lift No. 12 | 22 | 1 |

10.2 Observations and Findings

Describe observations and findings

11 ENERGY CONSUMPTION INFORMATION AND ANALYSIS - GENERAL EQUIPMENT AND PLUG LOADS

Describe typical list of equipment used, operation hours and rated power

Summary of total energy consumption measured from instantaneous power readings



12 ENERGY CONSUMPTION INFORMATION AND ANALYSIS - BUILDING CONTROL SYSTEM

12.1 System Description

Describe system/s

| No. | Description | Qty | Monitor/control | |
|-----|-----------------------------------|-----|-----------------|--|
| 1 | CHWP | | Control | |
| 2 | AHU | J9 | Control | |
| 3 | VAV | TVA | Control | |
| 4 | FCU | 46 | Control | |
| 5 | VRV | 56 | Control | |
| 6 | Lighting – General Area C Jy | NA | Control | |
| 7 | External Light | 296 | Control | |
| 8 | Car Park Lighti | NA | Monitor | |
| 9 | Ventilation Fans (Main Bldg only) | 138 | Control | |

Describe system operations

| System | Equipment | Control strategy | |
|----------|---------------------------|---|--|
| ctain | AHU | Fan speed is controlled by variable speed drive. Controlled variable is supply duct static pressure which is set at certain value. Control valve position is controlled by valve actuator. Controlled variable is supply air temperature. AHU operation is controlled by schedule program from BCS. | |
| 1 | VAV | VAV damper position is controlled by VAV actuator. Controlled valuable is one temperature. VAV position and a temperature are monitored by BC° | |
| ACMV | VRV 5 | V. V a m, er position is controlled by VAV actuator. Controlled variable is zone temperature. VRV position and zone temperature are monitored by BCS. | |
| | Ventilation/Fresh Air Fan | Fresh air fan operation hours are controlled by schedule program from BCS. Speed regulation of fresh air fan is controlled by Variable speed drive. Controlled variable is static pressure which varies according to fresh air damper position to each AHU. | |
| | Chilled water pump | Chilled water pump is controlled by variable speed drive Controlled variable is chilled water pressure differential between supply and return main. | |
| Lighting | Indoor General Areas | Lighting operation is controlled by schedule program from BCS | |

12.2 Observations and Findings


Describe observations and findings



13 LOAD APPORTIONING AND ENERGY INDEX

Describe chart.

| End Use Loads | Annual Consumption (kWh) | Percentage |
|---------------------|--------------------------------|------------|
| Cooling Energy | 2,281,310.00 | 28% |
| Lighting | 979987. 7 | 12% |
| General Plug Load | 35104 3 | 4% |
| Chilled Water Pumps | 28 75 ′ 64 | 3% |
| AHU | 2 85 722.14 | 30% |
| FCU and ACCU | 556365.12 | 7% |
| Ventilation Fa | 474451.85 | 6% |
| Rooftop Chiller | 118081.65 | 1% |
| VRV | 607505.74 | 8% |
| Lift | 12776.99 | 0.2% |




Energy Indices

Describe table and charts

| Building Energy Intensity Index (BEII) | kWh/m2 |
|---|--------|
| Lighting Energy Intensity Index (LEII) | kWh/m2 |
| Air Conditioning Energy Intensity Index (ACEII) | kWh/m2 |
| Building Power Baseload | kW |

| | (5) |
|--------------------------------|------|
| Lighting Power Density | W/m2 |
| Air Conditioning Power Density | W/m2 |
| Equipment Power Density | W/m2 |
| Baseload Power Index | W/m2 |



14 ENERGY SAVING MEASURES

Explain each esm in detail showing basis of calculations and assumptions made.

No low cost measure

Findings

Energy Saving Recommendation/Measure

Potential Annual Cost and Savings

Estimated Investment Cost

ROI/SPP

Medium cost measure

Findings

Energy Saving Recommendation/Measure

Potential Annual Cost and Savings

Estimated Investment Cost

ROI/SPP

High cost measure

Findings

Energy Saving Recommendation/Measure

Potential Annual Cost and Savings

Estimated Investment Cost

ROI/SPP

^{*} The ESMs shall address the energy management and energy efficiency. Renewable energy can be included but it is not part of the Energy Audit Conditional Grant scope.

Summary ESM table

| No. | ESM | Estimated Savings | | Estimated Investment(RM) | Simple Payback Period (yrs) | Estimated Carbon Reduction |
|---------|--|-------------------|------------|-----------------------------|--------------------------------|-------------------------------|
| | | Energy (kWh) | Cost (RM) | | | kgCO2/kWh |
| No Cos | t | | | | | |
| 1 | Decommissioning all non critical ACSU units when chiller plant has been retrofitted | 577587.64 | 306121.45 | 0 | Immediate | |
| Low/M | edium Cost | | | | | |
| 2 | Replace all Incandescent decorative lamps with LED strips/LED lamps | 28539.22 | 15, 5.7 | 1,000.00 | 0.07 | 21,147.56 |
| 3 | Switch off outdoor corridor lights during the daytime | 55442.8 | 20 4.71 | 80000 | 2.7 | 41,083.15 |
| 4 | Repairing compressed air leakage | 900.L | 2597.00 | 15000 | 5.8 | 3,630.9 |
| High Co | High Cost | | | | | |
| 5 | Retrofit chillers, chilled water pumps, condenser pumps, cooling tower and upgrade pipeworks | 380112.00 | 201459.36 | 1190000 | 5.9 | 281,662.9 |
| 6 | Retrofit AHUs and ducting to improve efficacy | 669384.00 | 354773.52 | 359000 | 1.0 | 496,013.54 |
| 7 | Replace all existing fluorescent and CFL lamps with LED lamps | 567599.96 | 300,827.98 | 482,640.00 | 1.60 | 420,591.57 |

'TO BE COMPLETED BY BUILDING OWNER'

- Financing options/Government Incentives available
- Guides on how to implement proposed energy saving measures
- Proposed action plan and estimated time required to implement each measure

15 ENERGY SAVING MEASUREMENT AND VERIFICATION

'TO BE COMPLETED BY ENERGY AUDITORS AND OWNER'

Types of baseline data:

- Past year bills
- Measurements

Measurement and Calculation methods

Measurement & Verification methods

16 FINANCIAL AND ENERGY SAVINGS MEASURES IMPLEMENTATION PLANNING FOR OWNER TO IMPLEMENT (3 YEARS)

'TO BE COMPLETED BY ENERGY AUDITORS AND BUILDING OWNER'


- 1ST Year, estimated implementation cost and savings.
- 2ND Year, estimated implementation cost and savings.
- 3rd Year, estimated implementation cost and savings.

^{*} The ESMs implementation planning shall address the energy management and energy efficiency. Renewable energy can be included but it is not part of the Energy Audit Conditional Grant scope.

17 CONCLUSION

Conclusion





Construction Industry Standard 2012 CIS20:2012 GreenPASS assessment scheme

18 VERIFICATION

| This Energy Audit Report is | | | | |
|-----------------------------|--------------|---------------------------|--|--|
| prepared by: | checked by: | received by SEDA Malaysia | | |
| | | | | |
| | | | | |
| | A PARTY POLY | | | |
| | ALDEVEL | | | |
| Name: | Name: | Name: | | |
| | | | | |
| Position: | Position: | Position: | | |
| ARREST 1887 | | | | |
| 1100-311 | | | | |
| Date: | Date: | Date: | | |

